

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**CHEMICAL OR RADIOLOGICAL MAXIMUM CONTAMINANT**  
**LEVEL (MCL) EXCEEDANCE**

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

**ICMSA - Rossiter Has Levels of HAA5's**  
**Above Drinking Water Standards**

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. Testing results we received on 09/6/2024 show that our system exceeds the standard, or maximum contaminant level (MCL), for HAA5's. The standard for HAA5's is 0.06 mg/l as determined by the Locational Running Annual Average (LRAA). The third quarter LRAA for HAA5's exceeded the MCL at location 741 at 0.10005 mg/l. The exceedance was found at Rossiter Water System.

**What should I do?**

**You do not need to use an alternative (e.g., bottled) water supply.** However, if you have specific health concerns, consult your doctor.

**What does this mean?**

This is not an immediate risk. If it had been, you would have been notified immediately. However, HAA5 compounds form when disinfectants react with natural organic matter in the water. People who drink water with HAA5's in excess of the MCL (maximum contaminant level) for many years may have an increased risk of getting cancer and may experience problems with their liver, kidneys or central nervous system. If you have a severely compromised immune system, have an infant, are pregnant or are elderly, you may be at risk and should seek advice from your health care provider.

**What happened? What was done?**

We exceeded the MCL for HAA5's for the third quarter of 2024 at one location as determined by the LRAA - locational running annual average. As per the DEP an average of the third quarter and the previous three quarter results is used for compliance. The average of the last 4 quarters was above the MCL and therefore out of compliance. To further lower HAA5's we will conduct distribution system optimization, including routine flushing and continuous chlorine monitoring as well as additional testing. The summer of 2024 baffles will be added to clear well.

\_\_\_\_\_ We anticipate resolving the problem within 90 days.  
\_\_\_\_\_

For more information, please contact Tricia Lefko, Compliance Superintendent at ICMSA, 602 Kolter Drive, Indiana, PA 15701, 724-349-6640, ext. 107 or by calling EPA's Safe Drinking Water Hotline 800-426-4791 or visiting our web site at [www.icomsa.org](http://www.icomsa.org).

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing*

3930-FM-BSDW0191 10/2015

*homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by ICMSA, 602 Kolter Dr., Indiana, PA 15701, 724-349-6640.

PWS ID#: 5320034

Date distributed 9/16/2024