



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

CHEMICAL OR RADIOLOGICAL MAXIMUM CONTAMINANT LEVEL (MCL) EXCEEDANCE

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

ICMSA Arcadia WTP Has Levels of Dichloromethane Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. Testing results we received on 9/28/2026 show that our system exceeds the standard, or maximum contaminant level (MCL), for Dichloromethane. The standard for Dichloromethane is 0.005 mg/l. Dichloromethane was found at a level of 0.008 mg/l in your drinking water.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

What happened? What was done? ICMSA is required to test for 21 drinking water VOC's or volatile organic compounds annually at the entry point. Samples taken in September showed that dichloromethane was above the MCL limit of 0.005 mg/l at 0.008 mg/l. A confirmation sample was taken two days after sample results were received from the laboratory. The confirmation sample came back non detect, no dichloromethane was detected.

We anticipate resolving the problem within The problem as been resolved as the confirmation sample detected no dichloromethane.

For more information, please contact Tricia Lefko, Compliance Superintendent at 724-349-6640, ext. 107.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by ICMSA.

PWS ID#: 5320041

Date distributed: 10/12/2026